



FORM 195
Rev. 09/20

COUNTY OF LOS ANGELES FIRE DEPARTMENT FIRE PREVENTION DIVISION

Fire Prevention Engineering
5823 Rickenbacker Road
Commerce, CA 90040
Telephone (323) 890-4125 Fax (323) 890-4129

Information on Fire Flow Availability for Building Permit

For One and Two Family Dwellings, Townhomes, and Accessory Dwelling Unit's

INSTRUCTIONS:

Complete parts I, II (A), & II (B)

Verifying fire flow, fire hydrant location and fire hydrant size.

PROJECT INFORMATION (To be Completed by Applicant)

PART I

Building Address: _____

City or Area: _____ APN _____

Nearest Cross Street: _____

Distance of Nearest Cross Street: _____

Property Owner: _____ Telephone: () _____

Address: _____

City: _____ Zip Code _____

Occupancy (Use of Building): _____ Fire Sprinklered: Yes No

Type of Construction _____

Square Footage: _____ Number of Stories: _____

Applicant's Signature

Date

PART II (A) INFORMATION ON FIRE FLOW AVAILABILITY
(Part II A and II B to be completed by Water Purveyor)

The distance from the fire hydrant to the property line is _____
feet via vehicular access. The fire flow services will be rendered from a _____
inch diameter water main. The hydrant is located on _____

(Direction/side) (Street)

(Feet) (Direction) of _____
(Nearest Cross - Street)
Static PSI _____ Residual PSI _____ Orifice size _____ Pitot _____
Fire Flow at 20 PSI _____ for one-hour duration Flow Test Date / Time _____
 Hydraulic model
Domestic Meter Size _____

PART II (B)

Water Purveyor Signature

Phone Number Date Title

PART III Conditions for Approval by the Building Department
(To be Completed by Building Department)

The building permit may be issued for new or additions to detached one and two family dwellings, townhomes, and accessory dwelling units when the above information is completed and shows that the following minimum requirements are met and the property is not located in a Fire Hazard Severity Zone.

- The water system is capable of delivering at least 1000 GPM at 20 PSI for one-hour if non-sprinklered
- The water system is capable of delivering at least 500 GPM at 20 PSI for one-half hour if sprinklered.
- The total area of the entire structure is less than 3,600 square feet.
- No portion of the lot frontage to the public fire hydrant shall exceed 450 feet via vehicular access.
- All portions of the proposed construction must be within 150 feet of a vehicular access roadway that is a minimum of 20 feet wide, paved with concrete or asphalt and does not exceed 15% grade.

APPROVED BY DATE OFFICE

This Information is Considered Valid for Twenty Four Months

When the project does not meet all of the above requirements for approval by the Building Department, the project must be sent to the Fire Prevention Division for approval before a Building Permit can be issued by the Building Department.